
- THIS DETAIL DOES NOT APPLY TO SINGLE-FAMILY HOME OR DUPLEX HOME IRRIGATION.
- BACKFLOW PREVENTION IS REQUIRED ON THE IRRIGATION LINE AS PER THE PLUMBING CODE.
- 3. PRIVATE HYDRANT SHALL BE CONNECTED AFTER THE BACKFLOW PREVENTER OF THE FIRE SERVICE.
- 4. HOT BOX TO BE INSTALLED WHERE REQUIRED BY SMCMUA. IRRIGATION EQUIPMENT MAY BE LOCATED IN A SEPARATE ENCLOSURE.
- SHUT-OFF VALVES SHALL BE LOCATED ADJACENT TO EACH OTHER, NOT STAGGERED, WITHIN THE RIGHT OF WAY.

### SCHEMATIC IRRIGATION, DOMESTIC AND FIRE SERVICE

(NOT TO SCALE)




SCHEMATIC SERVICE INSTALLATION DATE: 8/14/23

DESIGNED BY: PAD
CHECKED BY: SD
DRAWN BY: PAD

SCALE: SHEET:

- 1. DISTANCES ARE MEASURED FROM THE PROPERTY LINE TO THE MASTER METER ALONG THE CENTERLINE OF THE SERVICE LINE.
- 2. FIRE SERVICE AND DOMESTIC SERVICE SHALL NOT BE INTERCONNECTED WITHOUT THE APPROVAL OF SMCMUA.
- 3. BACKFLOW PREVENTION IS REQUIRED PER SMCMUA RULES AND REQULATIONS.
- 4. AN EXTERIOR DOOR WITH A KNOX BOX SHALL BE PROVIDED FOR SMCMUA ENTRY TO THE METER ROOM.
- 5. SERVICE MUST ENTER BUILDING AT THE POINT CLOSEST TO THE WATER MAIN. IF THE METER ROOM IS LOCATED AT THE REAR OF THE BUILDING, THE SERVICE WILL BE TREATED AS IF THE RUN IS LONGER THAN 130'.

SCHEMATIC
SINGLE BUILDING
(130 FEET OR LESS FROM PROPERTY LINE)
(NOT TO SCALE)




SCHEMATIC SERVICE INSTALLATION DATE: 8/14/23

DESIGNED BY: PAD
CHECKED BY: SD
DRAWN BY: PAD
SCALE: SHEET:

- 1. DISTANCES ARE MEASURED FROM THE PROPERTY LINE TO THE MASTER METER ALONG THE CENTERLINE OF THE SERVICE LINE.
- 2. HOT BOX SHALL BE LOCATED AS CLOSE TO THE RIGHT OF WAY AS POSSIBLE BUT NOT FURTHER THAN 130 FEET.
- 3. FIRE SERVICE AND DOMESTIC SERVICE SHALL NOT BE INTERCONNECTED WITHOUT THE APPROVAL OF SMCMUA.
- 4. BACKFLOW PREVENTION IS REQUIRED PER SMCMUA RULES AND REQULATIONS.

## SCHEMATIC SINGLE BUILDING (MORE THAN 130 FEET FROM PROPERTY LINE)

(NOT TO SCALE)



SCHEMATIC SERVICE INSTALLATION DATE: 8/14/23
DESIGNED BY: PAD

DESIGNED BY: PAD
CHECKED BY: SD
DRAWN BY: PAD
SCALE: SHEET:

DEVELOPMENTS/master documents/CAD details/development schematics dwo


- DISTANCES ARE MEASURED FROM THE PROPERTY LINE TO THE MASTER METER ALONG THE CENTERLINE OF THE SERVICE LINE.
- 2. HOT BOX SHALL BE LOCATED AS CLOSE TO THE RIGHT OF WAY AS POSSIBLE BUT NOT FURTHER THAN 130 FEET.
- 3. FIRE SERVICE AND DOMESTIC SERVICE SHALL NOT BE INTERCONNECTED WITHOUT THE APPROVAL OF SMCMUA.
- 4. BACKFLOW PREVENTION IS REQUIRED PER SMCMUA RULES AND REQULATIONS.
- IF REQUIRED FOR HYDRAULIC PURPOSES, THE SERVICES SHALL BE LOOPED ON SITE.

# SCHEMATIC MULTIPLE BUILDINGS (MORE THAN 130 FEET FROM PROPERTY LINE) (NOT TO SCALE)



SCHEMATIC SERVICE INSTALLATION DATE: 8/14/23

DESIGNED BY: PAD
CHECKED BY: SD
DRAWN BY: PAD
SCALE: SHEET:



- DISTANCES ARE MEASURED FROM THE PROPERTY LINE TO THE MASTER METER ALONG THE CENTERLINE OF THE SERVICE LINE.
- 2. FIRE SERVICE AND DOMESTIC SERVICE SHALL NOT BE INTERCONNECTED WITHOUT THE APPROVAL OF SMCMUA.
- 3. BACKFLOW PREVENTION IS REQUIRED PER SMCMUA RULES AND REQULATIONS.
- 4. AN EXTERIOR DOOR AND KNOX BOX SHALL BE PROVIDED FOR SMCMUA ENTRY TO THE METER ROOM.
- 5. IF REQUIRED FOR HYDRAULIC PURPOSES, THE SERVICES SHALL BE LOOPED ON SITE
- SERVICE MUST ENTER BUILDING AT THE POINT CLOSEST TO THE WATER MAIN.
   IF THE METER ROOM IS LOCATED AT THE REAR OF THE BUILDING, THE SERVICE WILL BE TREATED AS IF THE RUN IS LONGER THAN 130'.

## SCHEMATIC MULTIPLE BUILDINGS (130 FEET OR LESS FROM PROPERTY LINE)

(NOT TO SCALE)



SCHEMATIC SERVICE INSTALLATION DATE: 8/14/23
DESIGNED BY: PAD CHECKED BY: SD

DRAWN BY: PAD

SCALE: SHEET:

NTS 1 of 1