



#### NOTES:

1. BACKFILL TRENCH PER SPECIFICATIONS OR ROAD OPENING PERMIT.
2. SERVICE SADDLES SHALL BE REQUIRED FOR SERVICES THAT ARE 1-1/2" AND 2" DIAMETER.
3. METER PIT SHALL NOT BE LOCATED IN TRAFFIC AREAS. IF DRIVEWAY LOCATION IS UNAVOIDABLE SLAB TYPE CAST IRON FRAME AND COVER (CAMPBELL PATTERN NUMBER 1716) SET IN 30" X 30" X 4" THICK 3,800 PSI CONCRETE SHALL BE USED. A HOLE MUST BE CUT IN LID FOR AMR.

#### MATERIALS:

1. CORPORATION STOP: MUELLER MODEL B-25008N;
2. CURB STOP: MUELLER MODEL H-15209N ;
3. CURB BOX: BINGHAM AND TAYLOR CO., FIGURE 4901, COMPLETE WITH OLD STYLE LID;
4. SERVICE SADDLE: MUELLER SADDLE SERIES DR2S;
5. METER PIT: MUELLER THERMAL COIL METER BOX  
3/4" SERVICE: 250CS1842CCBSN  
1" SERVICE: 330CS1842CCBSN;
6. INSULATING PAD: MUELLER 4" THICK CLOSED CELL POLYETHYLENE FOAM
7. TEMPORARY SPACER: SCH 80 PVC, NSF APPROVED OR EQUALS
8. OR EQUALS

NO	DATE	REVISION

**SMCMUA**  
SOUTHEAST MORRIS COUNTY  
MUNICIPAL UTILITIES AUTHORITY  
19 SADDLE ROAD  
CEDAR KNOLLS, NJ 07927  
973-326-6180  
www.smcma.org

DETAIL  
COPPER SERVICE

DATE: 10/30/24  
DESIGNED BY: PAD  
CHECKED BY: -  
DRAWN BY: PAD  
SCALE: NTS  
SHEET: 1 of 1