



| METER SIZE         | LENGTH  |
|--------------------|---------|
| 5/8" & 5/8" X 3/4" | 7-1/2"  |
| 3/4"               | 9"      |
| 1"                 | 10-3/4" |
| 1-1/2"             | 13"     |
| 2"                 | 17"     |

NOTES :

1. ALL PLUMBING SHALL BE INSTALLED AS PER THE PLUMBING CODE.
2. 3/4" AND 1" METERS MAY BE REQUIRED TO BE INSTALLED IN A METER PIT AS DETERMINED BY SMCMA.
3. PIPING, COUPLING AND PIPE SUPPORTS SHALL BE SET IN PLACE BY CONTRACTOR FOR SMCMA METER INSTALLATION.
4. CONTRACTOR SHALL PROVIDE PLASTIC TO COPPER PIPE FITTINGS AND REDUCERS AS REQUIRED.
5. IF A PRESSURE REDUCING VALVE IS REQUIRED, IT SHALL BE INSTALLED DOWNSTREAM OF THE METER ASSEMBLY.
6. METERS MUST BE SET NEAR THE POINT OF ENTRANCE OF THE INLET PIPE INTO THE BUILDING.
7. METERS MUST BE LOCATED SO THAT THEY WILL BE PROTECTED FROM FREEZING OR OTHER DAMAGE.
8. METERS MUST NOT BE SET IN LOCATIONS WHERE ACCESS FOR READING AND MAINTENANCE IS RESTRICTED.

[illegible]

**SOUTHEAST MORRIS COUNTY  
MUNICIPAL UTILITIES AUTHORITY**  
19 SADDLE ROAD  
CEDAR KNOLLS, NJ 07927  
973-326-6880  
[www.smcmtua.org](http://www.smcmtua.org)

METER SETTING  
BUILDING INTERIOR  
COMMERCIAL

DATE: 4/9/25

DESIGNED BY: PAD

CHECKED BY: —  
DRAWN BY: PAD

|        |        |
|--------|--------|
| SCALE: | SHEET: |
| NTS    | 1 of 1 |